TYPE 1B CERTIFICATE OF PRODUCT CONFORMITY

ISSUED TO	WURTH GULF FZE Shop no: 12 3B Street - Umm Ramool - Dubai - United Arab Emirates Abdulrahman.Hussein Hussein Abdul-rahman Hussein CATEGORY MANAGER
PRODUCT DESCRIPTION	Weather Sealant
LOT/BATCH NUMBER	20251101005, 20251118039, 20251119039, 20251116037, 20251114005
QUANTITY	1200 pieces, 1500 pieces, 1500 pieces, 2500 pieces, 2500 pieces
MANUFACTURER	WURTH
STANDARD SPECIFICATIONS	AL SA'FAT 2023 2nd Edition
TITLE OF STANDARD	2023 Al Sa'fat Dubai Green Building System
SPECIFIC RULES NO	DM-DCLD-RD-CQPS-5109
SAMPLE ID NO/SENDER NO	NS-T1-2026-00006
TEST REPORT NO	170226317
PROJECT/PLOT DETAILS	-

ATTESTATION

Dubai Central Laboratory Department-Certification and Quality Control of Products Section hereby attests that the product as described above confirms to the requirements of the standard specifications as mentioned. This attestation is based on the results of tests conducted on samples selected from the above product using a sampling procedure given in the specific rules and evaluated as per attached Evaluation Report. It is applicable only to the product as described in this Certificate and does not cover the entire production of the factory

IAF eiaCI CB-099

DCL PRODUCT CONFORMITY

Manager Certification and Quality Control of Products Section

Dubai Central Laboratory Department

Certificate No: DCL-CE-T1-2026-5

Date Issued: 10-03-2026

Valid Up To: 09-03-2027

This certificate shall not be reproduced except in full and any alteration on this document will invalidate this certificate. The Evaluation Report mentioned above forms an integral part of this Certificate.This Document is electronically approved and does not required a signature.To verify the authenticity of this document please scan the above QR Code. This certification is in accordance with Certification Scheme Type 1b as described in ISO/IEC 17067:2013

حكومة دبي GOVERNMENT OF DUBAI	Organization/Unit:	إدارة مختبر دبي المركزي Central Laboratory Department	الوحدة التنظيمية:
	Document Title:	TYPE 1 CERTIFICATION - EVALUATION REPORT	عنوان الوثيقة:
	Doc Ref.	DM-DCLD-F-IC-5004	رقم الوثيقة:
بلدية دبي Dubai Municipality			

CLIENT NAME	WURTH GULF FZE
DATE	11-03-2026
PRODUCT DESCRIPTION	Weather Sealant
REFERENCE STANDARD	AL SA'FAT 2023 2nd Edition
SENDER NO.	NS-T1-2026-00006
APPLICATION NO.	BBCE-300126-P0000278

DETAILS OF EVALUATION:

REQUIREMENTS	STANDARD CRITERIA	RESULT	TESTING LABORATORY	TEST REPORT NO.	REMARKS
Volatile Organic Compound (VOC)	420 (g/L)(max)	15.69	Middle East Testing Services (METS Lab)	170226317	PASS
Volatile Organic Compound (VOC)	420 (g/L)(max)	15.69	Middle East Testing Services (METS Lab)	170226317	PASS
Volatile Organic Compound (VOC)	420 (g/L)(max)	15.69	Middle East Testing Services (METS Lab)	170226317	PASS
Volatile Organic Compound (VOC)	420 (g/L)(max)	15.69	Middle East Testing Services (METS Lab)	170226317	PASS
Volatile Organic Compound (VOC)	420 (g/L)(max)	15.69	Middle East Testing Services (METS Lab)	170226317	PASS

FINAL RECOMMENDATION
Since the above test results disclosed satisfactory conformance with the minimum requirements of Type 1 Product Certification, Specific Rules for Weather Sealant in accordance with the AL SA'FAT 2023 2nd Edition & DM-DCLD-RD-CQPS-5109, issuance of Certificate of Product Conformity on the above mentioned product is hereby recommended.

EVALUATED BY	**APPROVED BY**

Mohammad ali mohammad alustad alshehhi Senior Products Conformity Engineer	 ENG. MAJED AL SHAMSI Certification and Quality Control of Products Section Manager (CQPSM).
Date: 10-03-2026	Date: 11-03-2026

Approved/Authorized by CQPSM	درجة السرية/Level of Confidentiality : بيانات مفتوحه / OPEN DATA
Date of Issue: 11-03-2026	Rev. No.: 7
Date of update: 11-03-2026	Page 1 of 1